



Delta Cooling Towers, Inc.
41 Pine Street
P.O. Box 315
Rockaway, New Jersey 07866-0315
Telephone 973.586.2201
Fax 973.586.2243
www.deltacooling.com
sales@deltacooling.com

TM Series™ Induced Draft Cooling Tower Specifications

The TM Series™ cooling towers are induced draft counter-flow cooling towers with single module capacities from 250 to 2020 cooling tons. These towers are a modular design that Delta Cooling Towers introduced in 2001 and have been very well received in both commercial and industrial applications. There are three overriding principles that make TM Series™ cooling towers an excellent selection.

The towers are corrosion-proof not corrosion-protected which is an important distinction of Delta towers. Cooling towers are outdoor equipment, either on roofs or sides of buildings, and are subjected to weather extremes continuously. Delta towers are manufactured in a seamless engineered plastic (HDPE) structural shell which is corrosion-proof and will not rust, chip, peel, crack or ever need painting or additional protective coatings. Comparably priced towers are often sheet metal with a galvanized coating. Zinc galvanizing provides only an interim protection against corrosion. This galvanizing wears away, often unevenly, exposing sheet metal to the rapid corrosive environment of cooling tower duty.

The second principle of Delta towers is the engineering that led to a simplicity of design, translating into reliability and a trouble-free life of the towers. From the seamless cooling tower shell to the direct drive fan assembly, there are less overall components and systems within the tower to maintain. The towers are shipped factory complete with little more installation steps than hooking up the electrical and water. This design simplicity is recognized in many other industries as a key goal and leads to greater reliability and owner peace of mind.

Finally, the TM Series™ Induced Draft Cooling Towers are a high efficiency design which translates to very low energy costs to operate the towers. The design of the towers and the proprietary high efficiency fill material lead to this energy efficiency. The minimal operating costs, a track record of superior reliability and corrosion proof materials of construction makes the TM Series™ Induced Draft Cooling Tower the choice for cooling tower applications over 250 cooling tons.

TM SERIES™ INDUCED DRAFT COOLING TOWER

PART 1 GENERAL

1.1 SCOPE

Work included to furnish and install Delta Cooling Tower model TM-_____ consisting of all equipment necessary to provide a complete operating system to remove specified heat load. Cooling towers shall be packaged, factory pre-assembled to the fullest extent possible, induced draft, counter flow design

1.2 RELATED WORK

{insert related work document here}

1.3 REFERENCES - STANDARDS

AMCA - Air Moving and Conditioning Association
ASTM - American Society for Testing and Materials
ANSI - American National Standards Institute
ASME - American Society of Mechanical Engineers

1.4 QUALIFICATIONS

The cooling tower shall be manufactured by a company with at least 30 years experience manufacturer of seamless engineered polyethylene cooling tower systems.

1.5 WARRANTY

Shell shall be warranted for 15 years and all other equipment shall be warranted for one year against material and workmanship defects from date of shipment.

1.6 SUBMITTALS

Shop drawings shall be provided and shall include but not be limited to:

- A. System dimension
- B. Operating and dry weight
- C. Details of equipment
- D. Mounting and support requirements
- E. Descriptions and specifications

PART 2 PRODUCT

The cooling tower specified shall be factory assembled to the fullest extent possible.

2.1 Induced Draft Cooling Tower, Model TM-_____, _____ tons capacity, _____ GPM, _____ °F hot water temperature, _____ °F cold water temperature, _____ °F wet bulb temperature

A. Cooling tower

1. Shell shall be seamless, double wall, non-corrosive, hi-impact high density polyethylene (HDPE) of leak proof design. Conical transition for motor/fan assembly with separate polyethylene velocity recovery stacks. The shell shall exceed 1/4" average thickness. The structural shell shall be capable of withstanding water temperatures up to 160°F on a continual basis.
2. Sump shall be seamless, double wall, non-corrosive, hi-impact high density polyethylene (HDPE) of leak proof design. Sump will have I-Beam support pockets allowing placement on elevated I-Beams. Integral support posts 360° around sump give support to upper tower section and allow mounting of removable louvered air inlet panels for optimum air distribution.
3. Cooling tower structural shell & sump shall be guaranteed against corrosion for 15 years.
4. Cooling towers performance to be certified by CTI (Cooling Technology Institute) under CTI Standard-201.
5. Removable PVC louver panel located between sump support post for accessibility to automatic make-up valve and adjustable float.
6. PVC fittings shall be provided for inlet, outlet, overflow, drain and make up.
7. Outlet fitting for pump suction applications shall be provided with a vortex breaker.
8. Make up assembly shall be incorporated in the sump of the cooling tower. It shall be a mechanical valve assembly, adjustable height for varying operating condition.

The engineered plastic shell is the optimum material for cooling tower construction. The material is molded into a totally seamless shell, which will never leak, unlike conventional cooling towers which require many panels, joints, seams, seam gaskets, caulking and hundreds of bolts or other fasteners to maintain the integrity of the product. The Delta structural shell will never rust, chip, crack or ever need painting or further protective coatings. The structural shell is warranted for 15 years which is much longer than other available cooling towers

Galvanized steel towers provide only interim corrosion protection. The zinc galvanizing is designed only to delay corrosion as the zinc wears steadily away. Moderately high temperatures and various water chemical treatments speed up this leaching of zinc into the water or atmosphere. With only ounces per square foot of corrosion protection, it is only a matter of time till corrosion of the underlying sheet steel sets in.

Thin fiberglass panels can also not match the structural integrity of Deltas' seamless engineered plastic. Over time, if that long, leaks can develop at the joints even with gaskets and caulking applied. Thin fiberglass when exposed to the wide range of outdoor weather elements is also subject to delaminating, wicking and overall degradation.

B. Water distribution

Totally enclosed, non-corrosive, polyvinyl chloride (PVC) pipe with large orifice non-clog spray nozzle distribution system. Threaded nozzle orifices shall be interchangeable allowing substitution of larger diameter orifice for increased flow conditions without increasing inlet pressure.

C. Wet decking

Rigid PVC film, corrugated and bonded for maximum cooling efficiency.

D. Drift eliminator

Drift eliminator shall be three pass non-corrosive, polyvinyl chloride (PVC) corrugated and bonded, one-piece, with non-corrosive PVC straps for easy removal for internal inspection and maintenance.

E. Fan Assembly

1. Fan propellers shall be adjustable pitch direct drive. Fan blades shall be constructed of fiberglass reinforced polypropylene with aluminum silicon alloy hub and stainless steel hardware. Statically and dynamically balanced prior to shipping.
2. Fans and motors shall be supported by heavy gauge angled steel ring. The fan ring shall be coated with a premium Heresite for corrosion protection.

3. Motor shall be Totally Enclosed Air Over, Direct Drive, 900 RPM, Class F insulation, with 1.15 minimum service factor and specifically designed for cooling tower duty.
4. Motor shall be warranted against defects in materials and workmanship under motor manufacturer's warranty.
5. Fan guards shall be mounted to top of velocity recovery stacks. Guards shall be coated steel mesh, with 2 ¾" open area to allow air to pass through with minimum pressure loss while protecting personnel from contacting the rotating fan propeller.

Propeller type fan is attached to the shaft of the motor. The direct drive system has a twofold benefit. First and foremost, there are no extra bearings, pulleys, gear reducers or additional shafts to maintain or fail. The second benefit is the higher efficiency gained by connecting the motor to the motor shaft, there are no losses due to friction from bearings and gears, thus providing the highest efficiency available.

F. Hardware

All fasteners are 304 stainless steel. Anchoring lugs are Heresite coated steel.

PART 3 EXECUTION

1. GENERAL - INSTALLATION

Installation of equipment shall be in conformance with the manufacturer's recommendations.

2. TESTING

- A. Contractor shall perform all field testing and final adjustment of cooling tower equipment in accordance with provision of manufacturer.
- B. Contractor shall certify that all operation criteria are within normal operating range as specified by the manufacturer.
- C. Should any part of the cooling tower equipment fail to meet any specified requirement, adjust, repair or replace any and all defects or inoperative parts immediately with manufacturer's recommended parts or procedures.